

ORIGINAL

IFB No. SA 1213

**SANITARY SEWER MAIN LINING  
ANNUAL SERVICES CONTRACT**

**BID**

SUBMITTED TO: Prince William County Service Authority (Owner)  
4 County Complex Court  
P. O. Box 2266  
Prince William, VA 22195-2266

BY: AM-LINER EAST, INC, Bidder

1. The undersigned BIDDER proposes and agrees, if this Bid is accepted, to enter into an Agreement with OWNER in the form included in the Contract Documents, to complete all work as specified or indicated in the Contract Documents for the Contract Price and within the Contract Time indicated in this Bid and in accordance with the Contract Documents.
2. BIDDER accepts all of the terms and conditions of the Information for Bidders, including without limitation those dealing with the disposition of Bid Security. This Bid will remain open for 75 days after the day of Bid opening. BIDDER will sign the Agreement and submit the Contract Security and other documents required by the Contract Documents within ten days after receipt of Conformed Contract Documents from OWNER.
3. In submitting this Bid, BIDDER represents that:
  - (a) BIDDER has examined copies of all Contract Documents and of the following addenda:

Number(s): 1 2 3 \_\_\_\_\_

Date(s): 10/16/12 10/29/12 11/1/12 \_\_\_\_\_

(Receipt of all of which is hereby acknowledged) and also copies of the Notice to Bidders and the Information for Bidders;

- (b) BIDDER has examined carefully the site and locality where the Work is to be undertaken, and he has taken into consideration all site conditions affecting the cost of performing the work. He has considered the legal requirements (Federal, State and local laws, ordinances, rules and regulations) and all other conditions affecting the cost, progress or performance of the Work, whether represented in the Contract Documents or not, and he has made such other independent investigations as BIDDER deems necessary for the preparation of this Bid;

Bidder: AM-LINER EAST, INC.

(c) This Bid is genuine and not made in the interest of or on behalf of any undisclosed person, firm or corporation and is not submitted in conformity with any agreement or rules of any group, association, organization or corporation; BIDDER has not directly or indirectly induced or solicited any other Bidder to submit a false or sham Bid; BIDDER has not solicited or induced any person, firm or a corporation to refrain from bidding; and BIDDER has not sought by collusion to obtain for himself any advantage over any other Bidder or over Owner:

4. BIDDER will complete the work required for each work order as part of the Project for the amounts shown on the Schedule of Unit Prices attached hereto and totaling:

one million three hundred seventy-four thousand two hundred fifty-seven

fifty cents  
and ~~500~~ 0 /100 Dollars (\$ 1,374,257.50), subject to such adjustments as may be authorized the Contract Documents.

5. BIDDER agrees that the work will begin within 14 calendar days after the date of the Notice to Proceed on any given work order. The CONTRACTOR shall substantially complete the work in accordance with the time requirement of the work order. Furthermore, all the work will be completed and ready for final payment according to Article 11 of the General Conditions within thirty (30) days from the date of Substantial Completion for each sanitary sewer main lined using the CIPP method.
6. Required Bid Security in the form of a bid bond in an amount equal to one percent (1%) of this Bid is attached hereto.
7. Bidder does ( ), does not (✓) desire to exercise his prerogative under the provisions of Section 2.2-4334 of the Code of Virginia relating to Escrow Retainage.

Bidder: AM-LINER EAST INC

SUBMITTED this 8 day of November, 20 12

RESPECTFULLY SUBMITTED

Mel M. Willett

BY: Mel M. Willett

TITLE: Vice President

(SEAL)  
Corporate  
Bidder

NA

D.B.A. \_\_\_\_\_

(SEAL)  
Individual  
Bidder

NA

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

(SEAL)  
Partnership  
(SEAL)  
Bidder  
(SEAL)

D.B.A. \_\_\_\_\_

Note: One party to a joint venture will sign in appropriate space above. All other parties sign in the manner indicated above on a separate page attached hereto.

The Bidder shall provide Contact information below [to answer any questions regarding the bid].

Bidder: AM-LINER EAST, INC.

Contact Information

Name: Mel M. Willett  
Title: Vice President  
Telephone: 540-955-9671  
FAX: 540-955-2872  
E-mail: mwillett@amlinereast.com



**SCHEDULE OF UNIT PRICES**  
TO ACCOMPANY THE PROPOSAL OF BIDDER/CONTRACTOR

**SANITARY SEWER MAIN LINING (CIPP)**  
**ANNUAL SERVICES CONTRACT**  
**IFB NUMBER: SA 1213**

Item No.	Description	Unit Price	Estimated Quantity	Unit	Computed Total Price
1	CCTV Inspection (6 -10 inch pipe)	\$ 1.10	10,000	LF	\$ 11,000.00
1a	CCTV Inspection (6 -10 inch pipe) off-road	\$ 1.10	1000	LF	\$ 1,100.00
2	CCTV Inspection (12 -15 inch pipe)	\$ 1.10	5,000	LF	\$ 5,500.00
2a	CCTV Inspection (12 -15 inch pipe) off-road	\$ 2.00	500	LF	\$ 1,000.00
3	CCTV Inspection (18 -21 inch pipe)	\$ 1.10	5,000	LF	\$ 5,500.00
3a	CCTV Inspection ( 18 – 21 inch pipe ) off road	\$ 2.00	250	LF	\$ 500.00
4	CCTV Inspection (24 -30 inch pipe)	\$ 4.70	2000	LF	\$ 9,400.00
4a	CCTV Inspection ( 24 – 30 inch pipe) off road	\$ 6.50	1500	LF	\$ 9,750.00
5	Traffic Control four lane road	\$ 50.00	30	Day	\$ 1,500.00
5a	Bypass Pumping of sanitary sewer main (2 – 4 MGD)	\$ 475.00	30	Day	\$ 14,250.00
6	Heavy Cleaning (6 -10 inch pipe)	\$ 1.10	2,000	LF	\$ 2,200.00
6a	Heavy Cleaning (6 -10 inch pipe) off-road	\$ 1.40	500	LF	\$ 700.00
7	Heavy Cleaning (12 -15 inch pipe)	\$ 1.80	1,000	LF	\$ 1,800.00
7a	Heavy Cleaning (12 -15 inch pipe off-road)	\$ 2.35	250	LF	\$ 587.50
8	Heavy Cleaning (18 -21 inch pipe)	\$ 3.30	1,000	LF	\$ 3,300.00
8a	Heavy Cleaning ( 18-21 inch pipe) off road	\$ 5.35	200	LF	\$ 1,070.00
9	Heavy Cleaning (24 30 inch pipe)	\$ 3.80	1000	LF	\$ 3,800.00
9a	Heavy Cleaning ( 24 – 30 inch) off road	\$ 5.00	1000	LF	\$ 5,000.00
10	Grout excessive infiltration prior to lining	\$ 23.00	200	Gal	\$ 4,600.00
11	CIPP for 8" sanitary sewer main	\$ 31.00	10,000	LF	\$ 310,000.00
11a	CIPP for 8" sanitary sewer main (off-road)	\$ 37.00	100	LF	\$ 3,700.00
12	CIPP for 10" sanitary sewer main	\$ 31.00	2,000	LF	\$ 62,000.00
12a	CIPP for 10" sanitary sewer main (off-road)	\$ 37.00	250	LF	\$ 9,250.00
13	CIPP for 12" sanitary sewer main	\$ 32.00	2,000	LF	\$ 64,000.00
13a	CIPP for 12" sanitary sewer main (off-road)	\$ 39.00	250	LF	\$ 9,750.00
13	CIPP for 15" sanitary sewer main	\$ 43.00	2,000	LF	\$ 86,000.00
14a	CIPP for 15" sanitary sewer main (off-road)	\$ 49.00	250	LF	\$ 12,250.00

15	CIPP for 18" sanitary sewer main	\$ 53.00	2,000	LF	\$ 106,000.00
15a	CIPP for 18" sanitary sewer main (off-road)	\$ 65.00	250	LF	\$ 16,250.00
16	CIPP for 21" sanitary sewer main	\$ 57.00	3,000	LF	\$ 171,000.00
16a	CIPP for 21 inch sewer main (off road)	\$ 72.00	250	LF	\$ 18,000.00
17	CIPP for 24" sanitary sewer main	\$ 77.00	1500	LF	\$ 115,500.00
17a	CIPP for 24" sanitary sewer main ( off road)	\$ 90.00	1000	LF	\$ 90,000.00
18	CIPP for 30" sanitary sewer main	\$ 115.00	1000	LF	\$ 115,000.00
18a	CIPP for 30" sanitary main( off road)	\$ 136.00	500	LF	\$ 68,000.00
19	Robotic reinstatement and preparation of service lateral after installation of CIPP liner.	\$ 100.00	350	EA	\$ 35,000.00

TOTAL, ALL ITEMS: (\$ 1,374,257.50 )

TOTAL, ALL ITEMS: one million three hundred seventy-four thousand two hundred fifty seven dollars and fifty cents In Writing

ORDER: AM-LINER EAST, INC.



## Procurement Department

---

P.O. Box 2266 · Woodbridge, Virginia 22195-2266 · Fax (703) 335-7954

October 16, 2012

### Addendum # 1

#### IFB SA 1213 Sanitary Sewer Main Lining (CIPP)

---

THIS SOLICITATION IS HEREBY AMENDED AS FOLLOWS:

1. *The Questions Deadline and Bid Opening dates have been extended as follows:*

**QUESTIONS DEADLINE:** Submit questions, in written form only, to the Purchasing Manager at [purchasinggroupemail@pwcsa.org](mailto:purchasinggroupemail@pwcsa.org) no later than **5:00 p.m. (local time), October 31, 2012.**

**BID OPENING:** Pursuant to the competitive bidding provision of the Service Authority's purchasing regulation and the Code of Virginia, and subject to the terms and conditions listed herein, sealed bids will be accepted until **2:00 p.m. (local time), November 8, 2012** after which, responses will be opened then read aloud.

Note: The official time device shall be that as designated by the Purchasing Manager for Prince William County Service Authority.


**Mailing Address:** Prince William County Service Authority, Procurement Department, PO Box 2266, Woodbridge, VA 22195, Attn: Purchasing Manager

**Street Address:** Prince William County Service Authority, Procurement Department, 4 County Complex Court, Prince William, Virginia, 22192, Attn: Purchasing Manager

2. All other solicitation terms, conditions and provisions remain unchanged and in full force and effect.

**Acknowledgement:** Contractors submitting for the above named project shall take note of the following changes, additions, deletions, clarification, etc., in the Contract Documents, which shall become a part of and have precedence over anything shown or described in the Contract Documents, and as such shall be taken into consideration and be included in the Contractor's Bid Proposal. All other terms and conditions of the Invitation for Bid shall remain unchanged.

Bidders must acknowledge receipt of this amendment by signing and returning this addendum with the bid response prior to the bid opening date and time and shall acknowledge the receipt of this addendum where designated on the Bid Form.

	10/16/12
Authorized Signature	Date
Mel M. Willett	Vice President
Name Printed	Title
AM-LINER EAST, INC	
Company Name	

Direct all inquiries to: Mike Burke, Prince William County Service Authority, T: (703)335-8935/ F: (703)335-7954, E-mail: purchasinggroupemail@pwcsa.org

End of Addendum Number One





Procurement Department

P.O. Box 2266 • Woodbridge, Virginia 22195-2266 • Fax (703) 335-7954

October 29, 2012

Addendum # 2

IFB SA 1213 Sanitary Sewer Main Lining (CIPP)

THIS SOLICITATION IS HEREBY AMENDED AS FOLLOWS:

1. *In Part 2, General Requirements, replace Section 01501 Flow Control/Bypass Pumping in its entirety with the enclosed.*
2. All other solicitation terms, conditions and provisions remain unchanged and in full force and effect.

**Acknowledgement:** Contractors submitting for the above named project shall take note of the following changes, additions, deletions, clarification, etc., in the Contract Documents, which shall become a part of and have precedence over anything shown or described in the Contract Documents, and as such shall be taken into consideration and be included in the Contractor's Bid Proposal. All other terms and conditions of the Invitation for Bid shall remain unchanged.

Bidders must acknowledge receipt of this amendment by signing and returning this addendum with the bid response prior to the bid opening date and time and shall acknowledge the receipt of this addendum where designated on the Bid Form.



Authorized Signature

11/07/12

Date

Mel M. Willett

Name Printed

Vice President

Title

AM-LINER EAST, INC.

Company Name

Direct all inquiries to: Mike Burke, Prince William County Service Authority, T: (703)335-8935/ F: (703)335-7954,  
E-mail: purchasinggroupemail@pwcsa.org

End of Addendum Number Two

End of Addendum

## **SECTION 01501**

### **FLOW CONTROL/BYPASS PUMPING**

#### **PART 1 – GENERAL**

- 1.01. The Contractor shall be responsible for safely bypassing sewage flows around any sewer line, manhole, or sewage pumping station to be taken out of service for inspection, construction, lining or any other purpose and for completing the work without causing or contributing to any spills, discharges, leaks, or deposits of sewage in or to the environment, including the land, surface water, or groundwater, or backups in public or private buildings/property (collectively, “sewage spills”).

The Contractor shall furnish all labor, materials, equipment and supplies, and shall perform all work related to the control of sewage flow. Flow control and routing methods shall be subject to review by the Owner prior to work beginning at the sewer system components requiring flow control or bypass pumping.

#### **1.02. DEFINITIONS**

- A. Flow Control: Flow control shall consist of plugging, trucking, operation of pump stations, performing work during non peak flow hours, or other methods to control the flow in the gravity sanitary sewer system.
- B. Bypass Pumping: Bypass pumping shall consist of pumping arrangements used to bypass the gravity sanitary sewer flow in order to perform work on the gravity sanitary sewer system.

#### **1.03. SUBMITTALS**

- A. Bypass pumping arrangement plans
- B. Sample notification

#### **PART 2 – MATERIALS**

- 2.01 Not used.

#### **PART 3 – EXECUTION**

##### **3.01. NOTIFICATION**

- A. Contractor shall provide a sample notification to the Owner for review and approval prior to usage.
- B. Contractor shall provide the Owner written, 48 hours, advanced notification of any planned service interruptions.
- C. Contractor shall assume all responsibility for notification to and coordination with all customers whose service laterals or private pump stations will be out of service during the work. Notifications shall be in writing via door hanger, door flier, or U.S. mail.

Notification shall be given 48 hours in advance of loss of service (excluding weekends and holidays). Notice shall clearly state the purpose of the work, shall advise all affected customers against water usage until the service is reinstated, and shall clearly state the potential consequences of use of residential wastewater generating facilities during the time when the sewer service will be out of service (i.e. sewer back-up). The notice shall include the project name, project number, Owner's department name, Owner employee contact number, and Contractor's local 24-hour contact number for residents to call if they have questions regarding the work. The notice shall be in both English and Spanish.

### 3.02. FLOW CONTROL

- A. Flows shall be plugged, trucked, or otherwise handled to prevent flows from interfering with the work to be performed on a given portion of the sanitary sewer system.
- B. Flow control shall include the operation of public and private pump stations to control flows in the system as well as performing work during nighttime conditions to control flow in the system.
- C. The Contractor shall contact the Owner and private pump station operators to coordinate with the operation of the pumping stations discharging to the gravity sewer as required to perform the work. The Contractor shall not operate municipal or private pumping stations.

### 3.03. BYPASS PUMPING

- A. The Contractor shall provide sewage bypassing arrangement plans to the Owner at least 72 hours prior to commencing work on each portion of the system. The plans must be specific and complete, and shall include, but not be limited to, the following details:
  - 1. Provide justification that bypass plan is sufficient to accommodate existing flows.
  - 2. Capacities of pumping equipment.
  - 3. Road crossing details, including paved or unpaved roads, driveways, entrances, or other travelways.
  - 4. Protection against pipe breaks.
  - 5. Sewer plugging methods and bypass time duration for each sewer section.
  - 6. Size, length, material, and method of installation for suction and discharge piping.
  - 7. Method noise control for each pump and/or generator.
  - 8. Bypass pumping locations.

- B. Bypassed flows must be discharged to the sanitary sewer system, appropriate watertight vehicle or appropriate watertight container.
- C. The Contractor shall prepare/set up sewage pumping/bypass system prior to beginning work on any sewer pipeline or manhole activities. The system shall be activated when necessary to bypass flows for blockages resulting from the Contractor's activities in the vicinity of the sewer system.
- D. The pumping/bypass system shall be adequate in size to handle the flows in the system being worked on. The Contractor shall supply the necessary pumps, conduits, engines and other equipment to divert the flow of sewage as appropriate.
- E. In order to prevent the accidental spillage of flows, all discharge systems shall be temporarily constructed of pipe with positive, restrained joints. Under no circumstances will aluminum "irrigation" type piping or glued PVC pipe be allowed.
- F. The Contractor shall make all arrangements for by-pass pumping during the time when the sanitary sewer main is shut down for any reason.
- G. Ensure that all pumps and equipment employed by the Contractor are continuously monitored by an individual who is trained and qualified to start, stop, refuel and maintain this equipment during the work being performed by the Contractor. The Contractor shall select pumping/bypass equipment that will not have excessive noise levels from a maximum of sixty decibels (60 db) at a distance of fifty (50) feet.
- H. The design, installation, and operation of the temporary pumping system shall be the Contractor's responsibility. The by-pass system shall meet the requirements of all codes and regulatory agencies having jurisdiction.

#### 3.04. PRECAUTIONS

- A. When flow in a sewer line is plugged, blocked, or bypassed by the Contractor, the Contractor shall take precautions to protect the public health and to protect the sanitary sewer lines from damage resulting from sewer surcharging. Further, the Contractor shall take precautions to ensure sewer flow control operations do not cause flooding or damage to public or private property being served by the sewers involved and shall be responsible for any damage resulting from the flow control operations.
- B. When flow in a sewer line is plugged or blocked by the Contractor, the Contractor shall monitor the conditions upstream of the plug and shall be prepared to immediately start bypass pumping, if needed. Any liquid or solid matter that is bypass pumped from the sewer collection system shall be discharged to another sewer manhole or appropriate watertight vehicle or container only. No such liquid or solid matter shall be allowed to be discharged, stored, or deposited on the ground, swale, road, storm water drainage system, or open environment. The Contractor shall protect all pumps, conduit, and other equipment used for bypass from traffic.

3.05 CONTRACTOR'S RESPONSIBILITY FOR PROTECTION OF PUBLIC AND PRIVATE PROPERTY

- A. In the event of a Sewage Spill occurring in connection with the work being performed by the Contractor, the Contractor shall promptly clean up all spilled solid material, disinfect the affected area, and repair any damage to property, and shall do so at the Contractor's expense and at no cost to the Authority.
- B. In the event of a Sewage Spill occurring in connection with the work being performed by the Contractor, the Contractor shall promptly notify the Service Authority and comply with the currently adopted version of all Federal, State and Local regulations to include required notifications at the Contractor's expense and at no cost to the Authority. The Contractor shall provide an oral report to the Department of Environmental Quality (Department) within 24 hours from the time the Contractor becomes aware of the sewage spill and a written report to the Department within five (5) days of discovery at the following address and telephone number:

Department of Environmental Quality  
Northern Virginia Regional Office  
13901 Crown Court  
Woodbridge, VA 22193  
(703) 583-3800 (voice) or,  
(703) 583-3821 (fax)

For reports to the Department outside normal working hours, leave a message to fulfill the immediate notification requirement. If a sewage spill is considered to be an "emergency", based on volume, spill location, public health concerns, etc, and the sewage spill takes place after normal business hours, weekend or Holiday a call shall be made to the Virginia Department of Emergency Services at its 24-hour telephone service at 1-800-468-8892.

The written report shall contain: a description of the nature and location of the discharge; if the discharge reached State waters, the name of the affected water body; the cause of the discharge; the date on which the discharge occurred; the length of time that the discharge continued; the volume of the discharge, if the discharge is continuing, how long it is expected to continue; if the discharge is continuing, what the expected total volume of the discharge will be; and any steps planned or taken to reduce, eliminate and prevent a reoccurrence of the present discharge or any future discharges. The Contractor shall provide confirmation of immediate oral notification and a copy of the written report to the Service Authority.

The Contractor shall be charged back for any fines, penalties or other costs or damages incurred by the Service Authority as a result of a Sewage Spill occurring in connection with the work being performed by the Contractor.

**END OF SECTION**





Procurement Department

P.O. Box 2266 • Woodbridge, Virginia 22195-2266 • Fax (703) 335-7954

November 1, 2012

Addendum # 3

IFB SA 1213 Sanitary Sewer Main Lining (CIPP)

THIS SOLICITATION IS HEREBY AMENDED AS FOLLOWS:


1. *Questions and Answers:*

See attached

2. All other solicitation terms, conditions and provisions remain unchanged and in full force and effect.

**Acknowledgement:** Contractors submitting for the above named project shall take note of the following changes, additions, deletions, clarification, etc., in the Contract Documents, which shall become a part of and have precedence over anything shown or described in the Contract Documents, and as such shall be taken into consideration and be included in the Contractor's Bid Proposal. All other terms and conditions of the Invitation for Bid shall remain unchanged.

Bidders must acknowledge receipt of this amendment by signing and returning this addendum with the bid response prior to the bid opening date and time and shall acknowledge the receipt of this addendum where designated on the Bid Form.

	11/07/12
Authorized Signature	Date
Mel M. Willett	Vice President
Name Printed	Title
AM-LINER EAST, INC.	
Company Name	

Direct all inquiries to: Mike Burke, Prince William County Service Authority, T: (703)335-8935/ F: (703)335-7954,  
E-mail: purchasinggroupemail@pwcsa.org

End of Addendum Number Three

Q1: How much are the liquidated damages?

A1: There will be no liquidated damages associated with this contract, disregard any references to liquidated damages.

Q2: Could you please provide information regarding the pay items for the lining that includes "off road" work. Will the Contractor be responsible for clearing, grubbing, temporary road/easement construction, etc.?

A2: The Contractor will not be responsible for clearing, grubbing, temporary road/easement construction, but shall be responsible for damages (including ruts) caused by their vehicles (raking, seeding and, strawing) or any other damages caused.

Q3: Section 02735, sub section 1.06 submittals, paragraph A, sub paragraph 1, since this is an undefined scope how are we to address coordination issues, access, and timing issues at the time of bid?

A3: This is a Task Order based contract. Information specific to a job shall be submitted after a Task Order has been issued. Coordination will be between the Contract Administrator and the Contractor's on site Superintendant.

Q4: Section 02735, sub section 3.04 paragraph E states that the Contractor shall stop all visible leaks including those at service connections to achieve an acceptable watertight seal.

What product is to be used to achieve this? Grout? Top hat? t liner? Jansen process?

A4: Grout will be used.

Q5: Are there any minority requirements on this project?

A5: No

Q6: Is UV curing an acceptable curing process?

A6: No, steam or hot water curing shall be used.

Q7: Will this project have any CCTV requirements for newly installed pipe?

A7: There will be no newly installed pipe under this contract, only CIPP lined pipe. See section 02742 Television Inspection for details on CCTV requirements for CIPP lined pipe.

Offeror's Name AM-LINER EAST, INC.

# **RIDER CLAUSE**

## **Use of Contract by Members of the Northern Virginia Cooperative Purchasing Council and the Metropolitan Washington Council of Governments**

Request For Quote IFB SA 1213 – Sanitary Sewer Main Lining (CIPP). This clause is intended to allow a successful contractor to offer the goods and services of the bid to other member jurisdictions of the Northern Virginia Cooperative Purchasing Council and the Metropolitan Washington Council of Governments. If a mark is made in the YES column next to a member name, the pricing, terms and conditions of the final contract are offered to the appropriate member. The successful contractor may directly notify any member jurisdiction of the availability of the contract. Offering to sell goods and services as a result of this solicitation to other member jurisdictions is voluntary on the bidder's part. A member jurisdiction's participation in the contract is voluntary, also. Any jurisdiction obligated to participate in the contract is indicated in the body of the solicitation and contract.

The member jurisdiction(s) which awards the contract as a result of this solicitation is responsible for the award, etc. of its portion of the contract only.

Each member jurisdiction which purchases as a result of this offer will be responsible for placing orders directly with the successful contractor, arranging all deliveries, reconciling discrepancies and invoices, and issuing payments.

Failure to offer the terms and conditions of the contract to any member will neither disqualify a bidder nor adversely affect the award of the contract.

It is the awarded contractor's responsibility to notify the jurisdictions shown below of the availability of the Contract(s).

**BIDDER'S AUTHORIZATION FOR PARTICIPATION:-** (This form must be completed and returned with bid.)

YES	JURISDICTION	YES	JURISDICTION
<input checked="" type="checkbox"/>	City of Alexandria, VA	<input checked="" type="checkbox"/>	Loudoun County Sanitation Authority
<input checked="" type="checkbox"/>	Alexandria Public Schools	<input checked="" type="checkbox"/>	Loudoun County Government
<input checked="" type="checkbox"/>	Alexandria Sanitation Authority	<input checked="" type="checkbox"/>	City of Manassas, VA
<input checked="" type="checkbox"/>	Arlington County, VA	<input checked="" type="checkbox"/>	City of Manassas Park, VA
<input checked="" type="checkbox"/>	Arlington Public Schools	<input checked="" type="checkbox"/>	Maryland - National Capital Park & Planning Comm
<input checked="" type="checkbox"/>	City of Bowie, MD	<input checked="" type="checkbox"/>	Metropolitan Washington Airports Authority
<input checked="" type="checkbox"/>	City of College Park, MD	<input checked="" type="checkbox"/>	Metropolitan Washington Council of
<input checked="" type="checkbox"/>	Culpeper County, Virginia	<input checked="" type="checkbox"/>	Governments
<input checked="" type="checkbox"/>	District of Columbia	<input checked="" type="checkbox"/>	Montgomery Community College
<input checked="" type="checkbox"/>	District of Columbia Schools	<input checked="" type="checkbox"/>	Montgomery County, MD
<input checked="" type="checkbox"/>	District of Columbia Water & Sewer Auth	<input checked="" type="checkbox"/>	Montgomery County Public Schools
<input checked="" type="checkbox"/>	Northern Virginia Community College	<input checked="" type="checkbox"/>	Northern Virginia Community College
<input checked="" type="checkbox"/>	City of Fairfax, VA	<input checked="" type="checkbox"/>	Northern Virginia Planning District Commission
<input checked="" type="checkbox"/>	Fairfax County, VA	<input checked="" type="checkbox"/>	Prince George's County, MD
<input checked="" type="checkbox"/>	Fairfax County Public Schools	<input checked="" type="checkbox"/>	Prince George's County Public Schools
<input checked="" type="checkbox"/>	Fairfax County Water Authority	<input checked="" type="checkbox"/>	Prince William County, VA
<input checked="" type="checkbox"/>	City of Falls Church, VA	<input checked="" type="checkbox"/>	Prince William County Public Schools
<input checked="" type="checkbox"/>	Fauquier County, VA	<input checked="" type="checkbox"/>	
<input checked="" type="checkbox"/>	Fauquier County Schools	<input checked="" type="checkbox"/>	Town of Purcellville, VA
<input checked="" type="checkbox"/>	City of Frederick, MD	<input checked="" type="checkbox"/>	City of Rockville, MD
<input checked="" type="checkbox"/>	Frederick County, MD	<input checked="" type="checkbox"/>	Stafford County, VA
<input checked="" type="checkbox"/>	Frederick County Public Schools	<input checked="" type="checkbox"/>	Stafford County Public Schools
<input checked="" type="checkbox"/>	City of Gaithersburg, MD	<input checked="" type="checkbox"/>	City of Takoma Park, MD
<input checked="" type="checkbox"/>	George Mason University	<input checked="" type="checkbox"/>	Upper Occoquan Sewage Authority
<input checked="" type="checkbox"/>	City of Greenbelt, MD	<input checked="" type="checkbox"/>	Town of Vienna, VA
<input checked="" type="checkbox"/>	Town of Herndon, VA	<input checked="" type="checkbox"/>	Washington Metropolitan Area Transit Authority
<input checked="" type="checkbox"/>	Town of Leesburg, VA	<input checked="" type="checkbox"/>	Washington Suburban Sanitary Commission
<input checked="" type="checkbox"/>	Loudoun County Public Schools		