

Part 300. Standards

300-L2 Lighting Standards

Security Reference:	300-L2
Description:	Lighting Standards
Policy Reference:	Industry Standards
	Local Regulations
	State Legislation

Minimum Standard

- **Regulated States** – California, District of Columbia, Florida, Georgia, Illinois, Louisiana, Maryland, Nevada, New Jersey, New York, Oregon, Texas, Washington, Alabama, Connecticut, Kansas, Kentucky, Massachusetts, Montana, Missouri, New Hampshire, Rhode Island, **Virginia**
- **A minimum of ten (10) foot candle power at the face of the ATM or after-hour depository extending outward five (5) feet in all unobstructed directions.**
- A minimum of two (2) foot candle power extending outwards in all unobstructed directions fifty (50) feet from the face of the ATM and after-hour depository.
- A minimum of two (2) foot candle power in defined parking areas within sixty (60) feet of the ATM and after-hour depository. In the event the ATM or after-hour depository is located within ten (10) feet of the corner of the building and is generally accessible from the adjacent side, there shall be a minimum of two (2) foot candle power along the first forty (40) unobstructed feet of the adjacent side of the building.
- If the ATM or after-hour depository is located inside a accessible vestibule during any hours of darkness, a minimum of 10 foot candle power at the face of the ATM or after-hour depository extending outward five (5) feet in all unobstructed directions. There will be a minimum of two (2) foot candle power at the inside of the vestibule entry/exit door(s). A minimum of two (2) foot candle power extending outwards in all unobstructed directions fifty (50) feet from the vestibule entry/exit door. A minimum of two (2) foot candle power in defined parking areas within sixty (60) feet of the vestibule entry/exit door. In the event the vestibule entry/exit door is located within ten (10) feet of the corner of the building and is generally accessible from the adjacent side, there shall be a minimum of two (2) foot candle power along the first forty (40) unobstructed feet of the adjacent side of the building. In urban settings for which there is no defined Bank parking and the only access area is a public sidewalk, a minimum 2 foot candle power shall be for the first 5 unobstructed feet from the door. The minimum foot candle reading will also be limited to Bank controlled property lines.
- A minimum of two (2) foot candle power in the immediate area of the designated associate entrance/exit to the facility.

Part 300. Standards

- All lighting measurements are to be taken at 36 inches above the ground on a horizontal plane, **unless otherwise specified by state law or regulation (3/07)**.
- [Corporate Workplace](#) has overall responsibility of ensuring that bank properties remains in compliance.
- The minimum standard shall apply unless a greater standard is required by an applicable law for a particular facility location.

Non-Regulated States

- A minimum of ten (10) foot candle power at the face of the ATM or after-hour depository extending outward five (5) feet in all unobstructed directions.
- A minimum of one (1) foot candle power extending outwards in all unobstructed directions fifty (50) feet from the face of the ATM and after-hour depository.
- A minimum of one (1) foot candle power in defined parking areas within sixty (60) feet of the ATM and after-hour depository. In the event the ATM or after-hour depository is located within ten (10) feet of the corner of the building and is generally accessible from the adjacent side, there shall be a minimum of one (1) foot candle power along the first forty (40) unobstructed feet of the adjacent side of the building.
- If the ATM or after-hour depository is located inside a accessible vestibule during any hours of darkness, a minimum of 10 foot candle power at the face of the ATM or after-hour depository extending outward five (5) feet in all unobstructed directions. There will be a minimum of two (2) foot candle power at the inside of the vestibule entry/exit door(s). A minimum of one (1) foot candle power extending outwards in all unobstructed directions fifty (50) feet from the vestibule entry/exit door. A minimum of one (1) foot candle power in defined parking areas within sixty (60) feet of the vestibule entry/exit door. In the event the vestibule entry/exit door is located within ten (10) feet of the corner of the building and is generally accessible from the adjacent side, there shall be a minimum of one (1) foot candle power along the first forty (40) unobstructed feet of the adjacent side of the building. In urban settings for which there is no defined Bank parking and the only access area is a public sidewalk, a minimum 1 foot candle power shall be for the first 5 unobstructed feet from the door. The minimum foot candle reading will also be limited to Bank controlled property lines.
- A minimum of two (2) foot candle power in the immediate area of the designated associate entrance/exit to the facility.
- All lighting measurements are to be taken at 36 inches above the ground on a horizontal plane, unless otherwise specified by state law or regulation (3/07).
- [Corporate Workplace](#) has overall responsibility of ensuring that bank properties remains in compliance.
- The minimum standard shall apply unless a greater standard is required by an applicable law for a particular facility location.