



INTEC Group 3201 JERMANTOWN ROAD S U I T E 7 5 0 FAIRFAX, VA 22030 T: 703.359.9737 F: 703.359.9453

www.intecgroup.net

February 27, 2020

Re: Flagship Ventilation

540 Maple Avenue Vienna, VA 22180

Permit Number: 170370160

The addition of awnings at the first floor of the Flagship Carwash would adversely impact natural ventilation and air flow. We would like to preserve the existing openings as originally designed for cross ventilation and prevent the creation of dead air spots.

If you have any further questions or comments concerning this matter, please feel free to contact me at 703.359.9737. x115

Sinderely,

Jay Rivera